



JACKED ENCASING PIPE SYSTEM  
STEPS 1, 2 & 3 AS SHOWN.

JACKED ENCASING PIPE SYSTEM  
INSTALLATION OF JACKED ENCASING PIPE TO BE  
CARRIED OUT BY SPECIALIST PIPE JACKING  
COMPANY AUTHORIZED BY THE WATER AGENCY.

NOTES

1. ALL DIMENSIONS IN MILLIMETRES.
2. PIPE MATERIALS AND 'D' & 'd' TO BE AS SPECIFIED IN DESIGN DRAWING.
3. FULLY WELD STEEL ENCASING PIPES.
4. GROUTING MIX TO BE 1:1 (SAND:CEMENT) WITH A WATER:CEMENT RATIO 1:0.67 BY WEIGHT USING FINE WELL ROUNDED SAND. PLASTICISERS MAY BE USED OR FLYASH MIXES.

INSTALLATION OF BORED ENCASING PIPE

<b>Armidale</b> Dept of Public Regional Council <b>Infrastructure</b>	SCALES	APPROVED	D. MAUNDER	31/08/2016	SHEET 1 OF 1
	N.T.S	MANAGER ENGINEERING AND STANDARDS SUPPORT		DATE	
BURIED SEWER CROSSINGS BORED AND JACKED ENCASING PIPE DETAILS	DRWN	AS SHEET SIZE	DRAWING No	AMDT No	010-043
	DES	A3	010-043		
	CHKD				