



PLAN A
KERB RAMP DETAIL




SECTION A-A




SECTION B-B


MINIMUM 125mm THICKNESS OF CONCRETE, REINFORCED WITH SL82 MESH



PLAN B
MARKED FOOT CROSSING
(SHARED PEDESTRIAN/BICYCLE CROSSING)



PLAN C
AT PEDESTRIAN CROSSING (ZEBRA)



KERB RAMPS FOR ACUTE /
OBTUSE INTERSECTIONS

NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES
2. ALL RAMPS ARE TO BE ALIGNED WITH THE DESIRED DIRECTION OF PEDESTRIAN TRAVEL AND BE A MINIMUM OF 1200mm WIDE, INCREASING IN WIDTH IN 300mm INCREMENTS.
3. PEDESTRIAN CROSSINGS AND MARKED FOOT CROSSING RAMPS MUST LINE UP WITH CROSSING AND CORRESPONDING RAMP ON THE ON THE OTHER SIDE OF THE ROAD.
4. (i) FOR A MARKED FOOT CROSSING (SHARED PEDESTRIAN/BICYCLE CROSSING) SLOPING FACE OF RAMP SHOULD BE AS WIDE AS THE INSIDE OF PAINT LINES WITH A PUSH BUTTON ON IT AT A PRACTICAL WIDTH NO LESS THAN 1200mm.
(ii) AT PEDESTRIAN CROSSING (ZEBRA) THE SLOPING FACE OF THE RAMP SHOULD BE AS WIDE AS THE OUTSIDE EDGE OF THE ZEBRA STRIPES. WHERE THIS IS NOT POSSIBLE, THE RAMP SHOULD BE AT A PRACTICAL WIDTH NO LESS THAN 1200 WIDE. (REFER TO PLAN C)
(iii) AT MARKED FOOT CROSSINGS (PEDESTRIAN ONLY CROSSINGS) THE SLOPING FACE OF THE RAMP SHOULD BE AS WIDE AS THE INSIDE OF THE PAINT LINES. WHERE THIS IS NOT POSSIBLE, LOCATE RAMP CLOSE TO POST WITH A PUSH BUTTON ON IT, AT A PRACTICAL WIDTH NOT LESS THAN 1200mm.
5. EXPANSION JOINTS TO BE PROVIDED WHERE ENDS OF THE KERB RAMP ABUTS KERB AND GUTTER.
7. SEPARATE KERB RAMPS MUST BE USED FOR ADJACENT CROSSINGS AT INTERSECTIONS.
8. TACTILE INDICATORS ARE TO BE INSTALLED AT ALL KERB RAMPS AS PER THE DETAILS ON DRAWING SHEETS 2 & 3.
9. ALL RAMPS TO BE CONSTRUCTED IN 20MPA CONCRETE, SL82 MESH AND BROOM FINISHED.
10. WHERE RAMPS ARE CONSTRUCTED TO EXISTING GUTTER, DOWEL RAMP TO GUTTER.
11. TACTILE INDICATORS ARE NOT TO BE INSTALLED ON COMPLIANT RAMPS, REFER SHEET 2.

Armidale Regional Council Dept of Public Infrastructure	SCALES	APPROVED	D. MAUNDER	10/11/2016	SHEET 1 OF 1
	NTS	MANAGER ENGINEERING AND STANDARDS SUPPORT		DATE	
STANDARD KERB RAMPS		SURV	AS SHEET SIZE	DRAWING No	AMDT No
		DRWN	A3	030-069	
		DES			
		CHKD	CADFILE 030-069.dwg	DATE 10/11/2016	