



PLAN

NOTES

1. STANDARD INTER-ALLOTMENT STORMWATER DRAINAGE IS CONSIDERED OWNED BY AND IS TO BE MAINTAINED THOSE BENEFITING FROM THE SYSTEM.
2. ALL DIMENSIONS ARE IN MILLIMETERS.
3. LOCATE INSPECTION OPENINGS IN ACCORDANCE WITH APPROVED DESIGN DRAWING REQUIREMENTS.
4. ALL CONNECTION TYPES SHOWN IN THIS DRAWING ARE APPLICABLE TO RPP, FRC, RCP UNLESS OTHERWISE SHOWN.
5. PIT SHALL BE IN ACCORDANCE WITH ARC STANDARD DRAWINGS (MIN. 600 x 600 INTERNAL DIMENSIONS). PITS DEEPER THAN 1.2m ARE TO BE 900 X 900 WITH STEP IRONS.
6. PITS SHALL BE CONSTRUCTED FOR EACH ALLOTMENT CONNECTION AND AT ALL CHANGES IN DIRECTION. MAXIMUM DISTANCE BETWEEN PITS SHALL BE NO GREATER THAN 60m.
7. ALIGNMENT OF INTER-ALLOTMENT DRAINAGE IS TO BE A MINIMUM OF 1m FROM THE BOUNDARY AND CONTAINED IN AN EASEMENT OF AT LEAST 2m WIDE. WHERE DISCHARGE FROM A PUBLIC ROAD / RESERVE IS TO BE CARRIED THROUGH THE SYSTEM, DIMENSIONS ARE TO BE AMENDED TO A MINIMUM OF 1.5m AND 3m RESPECTIVELY.
8. WIDER EASEMENTS MAYBE REQUIRED FOR OVERLAND SYSTEMS OR LARGER OR DEEPER PIPED SYSTEMS.
9. CONSIDERATION WILL BE GIVEN TO REDUCE THE EASEMENT WIDTH IN CONSTRAINED SITES.

Armidale <i>Dept of Public Infrastructure</i> Regional Council	SCALES	APPROVED	D. MAUNDER	31/08/2016	SHEET 1 OF 1
	NTS	MANAGER ENGINEERING AND STANDARDS SUPPORT		DATE	
INTERALLOTMENT PROPERTY DRAINAGE CONNECTIONS	SURV	AS SHEET SIZE	DRAWING No	AMDT No	
	DRWN TY	A3	080-026		
	DES				
	CHKD MW	CADFILE 080-026.dwg	DATE 31/08/2016		