



NOTES

1. COMPRESSIVE STRENGTH F'_c FOR CAST INSITU CONCRETE TO BE A MINIMUM 32 MPa AT 28 days.
2. PROVIDE CLIMB IRONS WHERE PITS ARE DEEPER THAN 1200.
3. UNUSED STEP IRON HOLES TO BE RENDERED REFER 080-031.

Armidale <i>Dept of Public Infrastructure</i> Regional Council	SCALES NTS	APPROVED D. MAUNDER MANAGER ENGINEERING AND STANDARDS SUPPORT 31/08/2016 DATE	SHEET 1 OF 1	
	STANDARD PATHWAY GRATED KERB INLET PIT (RM 12)	SURV DRWN PD DES CHKD MW	AS SHEET SIZE A3	DRAWING No 080-037
		CADFILE 080-037.dwg	DATE 31/08/2016	